

Dennis L. Thompson, MPA EFO
Fire Chief & Director of Emergency Services

Chief Deputy
Robert Klinoff

Emergency Services Manager
Georgianna Armstrong

Deputy Chiefs
Phil Castle
Nick Dunn
Michael W. Cody
Brian S. Marshall



Christmas Tree Lots



Permits are required for the sale of Christmas trees. An inspection will be conducted to review the following:

- A Minimum of one 2A:10B:C fire extinguisher for every 50 feet of travel within tree lot.
- Maintain a minimum clearance of ten feet (10') between trees and any building or structures. Trees may not be stored or displayed beneath any overhanging portion of a building.
- Maintain a minimum aisle clearance of forty four inches (44") between rows of trees and thirty five inches (35") between rows of trees and fences.
- Provide fire department access to all portions of the lot or buildings on the lot that are greater than one hundred and fifty feet (150") from the access roads. Required fire lanes must be a minimum of twenty feet (20") wide.
- Access gates to tree lots must remain open at all times during business hours.
- All electrical installations (lighting, etc) must meet codes.

KERN COUNTY FIRE DEPARTMENT 5642 Victor Street Bakersfield, CA 93308
Telephone 661-391-7000 Fax 661-399-2915 TTY Relay 800-735-2929 www.kerncountyfire.org

Proudly Serving All Unincorporated Areas of Kern County and the Cities of Arvin, Bakersfield, Delano, Maricopa, McFarland, Ridgecrest, Shafter, Taft, Tehachapi and Wasco

